



水務署
Water Supplies Department

MAR 10 PM 12:24

BEP

香港灣仔告士打道七號入境事務大樓
Immigration Tower, 7 Gloucester Road, Hong Kong

電子郵件
e-mail wsdinfo@wsd.gov.hk

電話
Telephone 2829 4367

圖文傳真
Facsimile 2824 0578

檔號
Reference (6) in WSD 3321/16 Pt.1 T/J(265)

9 March 2016

The Jardine Engineering Corporation, Limited
5/F Tower A, Manulife Financial Centre,
223-231, Wai Yip Street, Kwun Tong,
Kowloon, Hong Kong

(Attn.: Mr David Kwong)

Dear Sir,

Approval of "AFA" Y Strainers

Your letters ref. MF168 dated 19 February 2016, MF173 dated 25 February 2016 and MF175 dated 1 March 2016 refer.

It is noted that the fittings described below have been accepted by the United Kingdom Water Regulations Advisory Scheme (WRAS) to have complied with the requirements of the United Kingdom Water Supply (Water Fittings) Regulations / Scottish Water Byelaws when correctly installed.

Name of Manufacturer: Jiwa Industries PTE Ltd

Country of Origin: China

Brand: AFA

Details of Fitting: Range of Y patterned strainers with blue epoxy coated bodies and stainless steel screen. Maximum working pressure 16.0 bar. Maximum operating temperature 85°. (Epoxy powder coating is fusion and under WRAS approval no. 1307514 and test report ref. AGA60009 issued by ETS-Testconsult Limited)

Model: 92

Size: DN50, 65, 80, 100, 125, 150, 200, 250 & 300

Marking: Flow arrow, size and G25 on body. Company logo, AFA and tech info on data plate

WRAS Approval Number: 1510338

Installation Requirements: R001

Expiry Date: 31 July 2018

In view of the acceptance by WRAS, this Authority has no objection to the use of the said fittings in fresh water supply plumbing systems subject to full adherence to Waterworks installation requirements. On the other hand, the installation of the above fittings in flushing water plumbing systems and fire services may be allowed subject to the compliance of the relevant Waterworks requirements. In particular, you are required to draw your customers' attention to the following installation requirements –

“Installation shall comply with the ‘Installation Requirements & Notes’ of the WRAS’s approval letter concerned.”

A condition of this acceptance is that the fittings to be installed should be replicas of the samples certified by WRAS and no modification should be made to the fittings. This acceptance may be withdrawn at any time if the standard of the fittings installed fails to meet that of the approved samples or if the fittings are found to be unsuitable for use in fresh water supply plumbing systems.

This acceptance is only applicable to the main body of the fittings, unless other specified.

For the use of the fittings in any project, the Acceptance Reference Number at the bottom of this letter must be quoted as a means of identification of acceptance of the fittings by this Authority.

Should you have any enquiries, please contact our Engineer Ms. K L FOK at tel. no. 2829 5657.

Yours faithfully,



(LAM Ching Man)
for Water Authority

c.c. WSD 3321/1/82] - without catalogue
E/CS(TS)1] - with soft copy only