



水務署
Water Supplies Department

總部 Headquarters

香港灣仔告士打道七號入境事務大樓 48 樓

48/F, Immigration Tower, 7 Gloucester Road, Wan Chai, Hong Kong

本署檔號 : (7) in WSD 3321/18 Pt.1 T/J(404)

Our ref.

來函檔號 :

Your ref.

電話 :

Tel.

傳真 :

Fax.

2824 0578

15 January 2019

The Jardine Engineering Corporation, Limited
5/F, Tower A, Manulife Financial Centre,
223-231 Wai Yip Street, Kwun Tong,
Kowloon, Hong Kong

(Attn.: Mr David KWONG)

Dear Sir,

**Approval of "AFA" Gate Valves
(General Acceptance No. B20190002)**

Your letters ref. BEP/EME/LET/MF306, BEP/EME/LET/MF316, BEP/EME/LET/MF320 and BEP/EME/LET/MF324 dated 16 April 2018, 24 September 2018, 7 November 2018 and 3 December 2018 respectively refer.

It is noted that the fittings described below have been accepted by the United Kingdom Water Regulations Advisory Scheme (WRAS) to have complied with the requirements of the United Kingdom Water Supply (Water Fittings) Regulations / Scottish Water Byelaws when correctly installed. This Authority accepts that the fittings described below based on the WRAS certificate and test reports ref. J23503 & J23504 both issued on 28 November 2018 by Nutek Systems (HK) Limited.


Name of Manufacturer: Jiwa Industries Pte Ltd

Country of Origin: the Mainland of China

Brand: AFA

Details of Fittings: Range of blue epoxy coated gate valves with ductile iron bodies and EPDM encapsulated, ductile iron wedges. Supplied either hand wheel or cap operated. Maximum working pressure 16.0 bar. Maximum operating

temperature 70°C. (with epoxy powder coating under WRAS approval no. 1603543)

- Model:** 933G and 933S
- Size:** 50mm, 65mm, 80mm, 100mm, 125mm, 150mm, 200mm, 250mm, 300mm
- Body Markings:**  AFA, size (DN), PN rating and flow arrow on valve body

WRAS Approval Number: 1611072

Installation Requirements: R001

Expiry Date: 31 March 2021

In view of the acceptance by WRAS, this Authority has no objection to the use of the said fittings in fresh water plumbing systems, flushing water plumbing systems and fresh water fire services systems subject to full adherence to Waterworks installation requirements. In particular, you are required to draw your customers' attention to the following installation requirements –

“Installation shall comply with the ‘Installation Requirements & Notes’ of the WRAS’s approval letter concerned.”

A condition of this acceptance is that the fittings to be installed should be replicas of the samples certified by WRAS and no modification should be made to the fittings. This acceptance may be withdrawn at any time if the standard of the fittings installed fails to meet that of the approved samples or if the fittings are found to be unsuitable for use in the water supply systems mentioned above.

For the use of the fittings in any project, the General Acceptance Number of this letter must be quoted as a means of identification of acceptance of the fittings by this Authority.

Should you have any enquiries, please contact our Engineer Mr. Terry KUNG at tel. no. 3583 4086.

Yours faithfully,


(CHAN Chung-kun)

for Director of Water Supplies

Encl.

c.c. WSD 3321/1/82] - without catalogue
ME/MC] - with soft copy only