



水務署
Water Supplies Department

總部 Headquarters
香港灣仔告士打道七號入境事務大樓 48 樓
48/F, Immigration Tower, 7 Gloucester Road, Wan Chai, Hong Kong

本署檔號 : (10) in WSD 3321/2022 T/J(433/2022)
Our ref.
來函檔號 :
Your ref.

電話 :
Tel.
傳真 : 2824 0578
Fax.

19 August 2022

The Jardine Engineering Corporation, Limited
5/F, Tower A, Manulife Financial Centre,
223-231 Wai Yip Street, Kwun Tong,
Kowloon, Hong Kong

(Attn.: Mr David KWONG)

Dear Sir,

**Approval of "AFA" Butterfly Valves
(General Acceptance No. B20220019)**


Your letter ref. EME/LET/35/043 dated 22 April 2022 and subsequent submissions received by this department up to 22 July 2022 refer.

It is noted that the fittings described below have been accepted by the United Kingdom Water Regulations Advisory Scheme (WRAS) to have complied with the requirements of the United Kingdom Water Supply (Water Fitting) Regulations / Scottish Water Byelaws when correctly installed. This Authority accepts that the fittings described below based on the WRAS certificates and test report ref. 214661PC210441A issued on 1 June 2022 by Fugro Technical Services Limited comply with, and their use when correctly installed does not contravene, the Waterworks Ordinance and Regulations.

Name of Manufacturer: Jiwa Industries Pte Ltd
Country of Origin: the Mainland of China
Brand: AFA
Details of Fitting: Cast iron wafer type butterfly valve with epoxy coating under WRAS approval no. 2104506
Model: BW-9911L(G)



Size: 65mm, 80mm, 100mm, 125mm, 150mm, 200mm, 250mm & 300mm

Body Markings: AFA , Dn size, body material, disc material, Tmax, Pmax, on data plate.

WRAS Approval Number: 2201801

Installation Requirements: R001
(Appendix A of WRAS approval letter refers)

Expiry Date: 30 April 2026

In view of the acceptance by WRAS, this Authority has no objection to the use of the said fittings in fresh water plumbing systems, flushing water plumbing systems and fresh water fire services systems subject to full adherence to Waterworks installation requirements. In particular, you are required to draw your customers' attention to the following installation requirements –

“Installation shall comply with the ‘Installation Requirements & Notes’ of the WRAS’s approval letter concerned.”

A condition of this acceptance is that the fittings to be installed should be replicas of the samples certified by WRAS and no modification should be made to the fittings. This acceptance may be withdrawn at any time if the standard of the fittings installed fails to meet that of the approved samples or if the fittings are found to be unsuitable for use in the water supply systems mentioned above.

For the use of the fittings in any project, the General Acceptance Number of this letter must be quoted as a means of identification of acceptance of the fittings by this Authority.

Should you have any enquiries, please contact our Engineer Ms Winnie LO at tel. no. 3583 4086.

Yours faithfully,



(YAU Hau Yin)

for Director of Water Supplies

Encl.

c.c. WSD 3321/1/82] - without catalogue
ME/MC] - with soft copy only

General Acceptance No. B20220019