



水務署
Water Supplies Department

總部 Headquarters
香港灣仔告士打道七號入境事務大樓 48 樓
48/F, Immigration Tower, 7 Gloucester Road, Wan Chai, Hong Kong

本署檔號 : (4) in WSD 3321/2022 T/J(1305/2022)
Our ref. :
來函檔號 :
Your ref. :

電話 :
Tel. :
傳真 : 2824 0578
Fax. :

19 January 2023

The Jardine Engineering Corporation Limited
5/F., Tower A, Manulife Financial Centre,
223-231 Wai Yip Street, Kwun Tong,
Kowloon, Hong Kong


(Attn.: Mr David KWONG)

Dear Sir,

**Approval of "AFA" Check Valves
(General Acceptance No. C20230014FS)**

Your letters ref. EME/LET/35/055 and EME/LET/35/059 dated 14 November 2022 and 13 December 2022 respectively refer.

Having considered the test report ref. 222770PC220165A issued on 6 December 2022 by Fugro Technical Services Limited, this Authority accepts that the fittings described below comply with, and their use when correctly installed does not contravene, the Waterworks Ordinance and Regulations.

Name of Manufacturer: Jiwa Industries Pte Ltd
Country of Origin: the Mainland of China
Brand: AFA
Details of Fittings: Cast iron wafer type check valve
Model: 977
Size: 65mm, 80mm, 100mm, 125mm, 150mm, 200mm, 250mm, 300mm
Body Markings:  AFA size in DN ←



Expiry Date: 8 October 2027

Proviso: The fittings can only be used in fresh water fire service systems.

This Authority hereby permits the use of the above fittings in fresh water fire service systems subject to full adherence to Waterworks installation requirements.

A condition of this acceptance is that the fittings to be installed shall be replicas of the samples as certified by the testing agent mentioned above and without modifications. This acceptance may be withdrawn at any time if the standard of the fittings installed fails to meet that of the approved samples or if the fittings are found to be unsuitable for use in fresh water fire service systems.

For the use of the fittings in any project, the General Acceptance Number of this letter must be quoted as a means of identification of acceptance of the fittings by this Authority.

Should you have any enquiries, please contact our Engineer Ms Winnie LO at tel. no. 3583 4086.

Yours faithfully,

(YAU Hau Yin)

for Director of Water Supplies

Encl.

c.c. WSD 3321/1/82] - without catalogue
ME/MC] - with soft copy only